

Inc. Village of Russell Gardens
6 Tain Drive, Great Neck, N.Y. 11021
(516)482-8246/ Fax# (516) 482-8259

CERTIFICATION FOR A GAS TEST

For Office Use Only

Gas Test No. _____

Building Plumbing

Check One Box

Permit No. _____

MERCURY / AIR TEST

circle one of the above

Date: _____

Location: _____

New York State Uniform Fire Prevention and Building Code Subchapter G - Reference Standards - OSHA: Safety and Health.

Regulations for Construction <RS-35-4> - Part 1910-Occupational Safety and Health Standards- Subpart H - Hazardous Materials. 1910. - Storage and handling of liquified petroleum gases- 1910.110(b) Basic rules-1910.110(b)(8)piping-1910.110(b)(8)(ix)All piping, tubing, or hose shall be tested after assembly and proved free from leaks at not less than normal operating pressures. After insulation, piping and tubing of all domestic and commercial systems shall be tested and proved free of leaks using a manometer or equivalent device that will indicate a drop in pressure. Test shall not be made with a flame.

Witnessed by _____
Name Title

After all gas piping is fitted and fastened and all outlets capped, there must be applied by the plumber, in the presence of the Building Inspector, a test with air pressure equal to a column of mercury six (6) inches of height, or a minimum of Five (5) psi, the same to stand for ten (10) minutes. Only an approved gauge shall be used.