

Village Maintenance Report

To: Mayor David Miller

CC: Deputy Mayor Larry Chaleff and Village Trustees

From: Brian Gauger, Motor Equipment Operator

Date: April 28, 2022

Re: April 2022 Maintenance Report

- 1. General Village Maintenance:** All of the sprinkler systems were turned on and the timers were installed and tested. Any repairs or adjustments needed were made. The infrastructures for the security cameras were installed on Dunster Road. We are currently working on the infrastructures at Melbourne Road and Darley Road, the park will follow. The traffic triangle at Clent Road was weeded and cleaned. We have started our weekly landscaping at all village properties (ex. Mowing lawns, weeding, garbage removal)
- 2. Street Light Maintenance:** There were two outages this month. The light at 22 Carlton Road was out and was found to be a bad photocell. The photocell was replaced and tested for proper function. The other outage was between 300-304 Melbourne Road, which was found to be a bad ballast and the fixture was removed and replaced with a retro-fitted LED fixture. The street light on Darley Road by the apartment house was found to be a day-burner. The photocell will need to be replaced. The pole at this location was rotted but will also need to be re-located in the future when we do the infrastructure to install for the security cameras. An inventory was done on all the street lights in the village to assure proper count for the future lighting project.