

Village Maintenance Report

To: Mayor David Miller

Cc: Deputy Mayor Larry Chaleff and Village Trustees

From: Brian Gauger

Date: December 3, 2024

Re: November Maintenance Report

1. General Village Maintenance: The street sweeper has been going out daily. The Gehl's pistons were reinstalled. We rented a tow-behind air compressor and blew out all the villages sprinkler systems. Another village entrance sign was sanded epoxied and varnished, and reinstalled. The village purchased a new leaf vac and trailer to help reduce the number of trips to the dump. The 1993 International went to Syosset trucks for its annual preventative maintenance and inspection.

2. Street Lighting: The light in the middle of the Joyce Cohn Pathway was out. There were a few issues to be found. The light socket needed to be replaced, and the electrician found there to be a bad neutral at the electrical drop on the pole. PSEG came in and replaced the neutral. We replaced the light fixture in the building departments office due to a bad ballast.